QC-ABSTRACT

Name of Work:- Maintenance of Burial Ground In Bahubali Nagar In Ward No 16, BBMP, Bangalore.

Sl No.	Item	Quantity As Per BOQ	Required No's of tests	Actual No's of tests	Tests
1	PCC M10	29.87 Cum	1	1	Cement
					Sand, Aggregates
2	Steel	4.68 Tonne	1	1	-
3	Blocks	475.90 Sqm	1	1	Compressive Strength
4	M20	50.97 Cum	5	5	Concrete Cube Compressive Strength

Cubes

0-5 m^3	1set
6-15 m^3	2set
16-30 m^3	3set
31-50 m^3	4 set

Add 1set for every 50 Cum

CIVIL QUALITY CONSULTANTS & ENGINEERS Bangalore

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಧಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Scanned with CamScanner